



中国国家强制性产品认证证书

证书编号: 2011010305470728

委托人名称、地址

Steute Technologies GmbH & Co. KG
Brueckenstrasse 91, 32584 Loehne, Germany

生产者(制造商)名称、地址

Steute Technologies GmbH & Co. KG
Brueckenstrasse 91, 32584 Loehne, Germany

生产企业名称、地址

Steute Technologies GmbH & Co. KG
Brueckenstrasse 91, 32584 Loehne, Germany

产品名称和系列、规格、型号

拉线开关

ZS 75..., Ex ZS 75...; Uimp:6kV; Ui:400V; Ith:6A; AC-15:le/Ue:6A/400V; 外壳防护等级:IP54(ZS 75 VD, ZS 75 VS, ZS 75 WVS, ZS 75 S VS, ZS 75 SR VS); IP65:(ZS 75 S VD, ZS 75 SR VD, Ex ZS 75); 详细型号解释见附件

产品标准和技术要求

GB/T14048.5-2017

上述产品符合强制性产品认证实施规则 CNCA-C03-02:2014 的要求, 特发此证。

发证日期: 2019年05月08日 有效期至: 2021年05月06日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书为变更证书, 证书首次颁发日期: 2011年05月06日

本证书的相关信息可通过国家认监委网站 www.cnca.gov.cn 查询



主任:

陆梅



中国质量认证中心



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

CERTIFICATE NO.: 2011010305470728

NAME AND ADDRESS OF THE APPLICANT

Steute Technologies GmbH & Co. KG
Brueckenstrasse 91, 32584 Loehne, Germany

NAME AND ADDRESS OF THE MANUFACTURER

Steute Technologies GmbH & Co. KG
Brueckenstrasse 91, 32584 Loehne, Germany

NAME AND ADDRESS OF THE FACTORY

Steute Technologies GmbH & Co. KG
Brueckenstrasse 91, 32584 Loehne, Germany

PRODUCT NAME, MODEL AND SPECIFICATION

Pull-wire Switch

ZS 75...,Ex ZS 75...;Uimp:6kV;Ui:400V;Ith:6A; AC-15:Ie/Ue:6A/400V;IP54(ZS 75 VD,ZS 75 VS,ZS 75 WVS,ZS 75 S VS,ZS 75 SR VS);IP65:(ZS 75 S VD,ZS 75 SR VD,Ex ZS 75);

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T14048.5-2017

This is to certify that the above mentioned product(s) complies with the requirements of implementation rules for compulsory certification(REFNO.CNCA-C03-02:2014).

Valid from: May.08,2019

Valid until: May.06,2021

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

Date of original issued: May.06,2011

The certificate information is available through CNCA's website: www.cnca.gov.cn



President:

Lu Mei



CHINA QUALITY CERTIFICATION CENTRE



中国国家强制性产品认证证书

附 录

第 1 页 共 1 页

证书编号: 2011010305470728

纸 号: 2303420

型号的解释:

ZS	75	S	1NC/1NO
I	II	III	IV

I. Basic Type: 基本类型

- ZS / snap action; 瞬动
- Ex ZS / For sale in North China 北方极端环境

II. Type of Switch: 开关类型

- 75: Product Series Pull-wire-Switch No.75 拉线开关产品系列号 75

III. Actuator Type 操动头类型

- Blank (Basic Type) 基本型号
- S (two side actuation) 两边驱动
- SR (belt alignment switch) 防跑偏开关

IV. Contact Type

- 1Ö / 1S(x) 1NC / 1NO (1 normal closed _ 1 normal open) 1 常闭/1 常开
- 2Ö / 2S(x) 2NC / 2NO (2 normal closed _ 2 normal open) 2 常闭/2 常开
- 4Ö 4NC (4 Normal closed) 4 常闭

(x):

- VD push button release 释放按钮
- WVD watertight collar, push button release 带防水套, 释放按钮
- VS key release 钥匙释放
- WVS watertight collar, key release 带防水套, 钥匙释放
- W watertight collar 带防水套

注: 此附录与证书同时使用时有效。



主任: 陆杨



中国质量认证中心